## HUMBOLDT COUNTY BUILDING DEPARTMENT CITY OF WINNEMUCCA BUILDING DEPARTMENT SUBMITTAL LIST FOR FIRE ALARM SYSTEMS

Referenced Codes: 2012 International Fire Code (IFC), Nevada Administrative Code 477 (NAC 477) and National Fire Protection Association 72 (NFPA 72)

The following construction documents are required to be submitted for review and approval prior to any system installation. A permit must be obtained before any work begins. (This permit will include both building review and fire code review). Deviations form approved plans shall require permission of authority have jurisdiction.

 1.	Floor plans of each floor identified which indicates the use of all rooms (drawn to scale).
 2.	Location of all rooms (drawn to scale).
 3.	Location of all alarm initiating and notification appliances (with a device legend).
 4.	Alarm control and trouble signaling equipment.
 5.	Annunciation
 6.	Power connection
 7.	Battery calculation
 8.	Conductor type and sizes
 9.	Voltage drop calculation
 10.	Manufacturers specifications on all equipment, devices and materials listing model numbers and listing information.
 11.	Details of ceiling height and construction
 12.	The interface of the fire safety control functions
 13.	Monitoring information
 14.	Plans designed by a Nevada licensed fire alarm company with license number. (Nevada State Fire Marshal license). Signed by designer with company name, address and telephone number. Can also be designed by a Nevada licensed fire protection engineer.
 15.	Plans must include the address of the proposed installation and owners name, mailing address and telephone number.
 16.	Design criteria stated on plans indicating applicable codes or other design criteria.
 17.	Type of building construction and occupancy group.
 18.	Type of fire alarm system.
19	Date plans were drawn